

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7315-1130:190 Page 1 of 1

**CATEGORY:** Power Units

**LISTEE:** Honeywell International Inc., 1500 West Dundee Road, Arlington Heights, IL 60004  
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

**DESIGN:** Models XLS-BPS and XLS-BPS-220 Power Booster/Supply Units. Unit is designed to extend a fire alarm panel's notification circuit. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** XLS-BPS: 120 VAC input, 24 VDC output  
XLS-BPS-220: 220 VAC input, 24 VDC output

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For fire alarm use, the unit must be fully supervised and the standby batteries must provide 24 hours standby power during power loss.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as booster/power supply units for use with separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation.

**XLF:** \*7315-1591:192 Formerly 7315-1388:217

\*Rev. 05-25-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager